

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Masonite Architectural

1205 E 5th Avenue, Tampa, FL, United States

1401 East Fourth Street, Marshfield, WI, United States; 980 Point Township Drive, P.O. Box 112, Northumberland, PA 17857, United States; 506 Municipal Drive, Jefferson City, TN 37760, United States; 430, Route 108, Quest Saint-Ephrem, Quebec G0M 1R0, Canada

For the following product(s):

See Addendum

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 (effective January, 2017) for the school classroom<sup>1</sup> parameter.

<sup>1</sup> Modeled Product Type: Door (3ft x 7ft)

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-IAQ-04501

Valid from: July 1, 2023 to June 30, 2024



INDOOR ADVANTAGE GOLD  
BUILDING MATERIALS



**SCS**global  
SERVICES

A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

# Certification Addendum

## Masonite Architectural

Certification: Registration # SCS-IAQ-04501 | Valid from: July 1, 2023 to June 30, 2024

### Indoor Advantage™ Gold

Addendum Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conformance: Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 (effective January, 2017) for the school classroom<sup>1</sup> parameter.  
<sup>1</sup> Modeled Product Type: Door (3ft x 7ft)

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m3 (in compliance with CDPH/EHLB Standard Method v1.2-2017)

#### Products:

Standard and Environmental Doors with cores of the following type:

Acoustic, Agrifiber, Fire Resistant Composite, High Density Fiberboard (HDF), Hollow Core, Laminated Veneer Lumber (LVL), Lead, Particleboard (Standard and NAUF), Staved Lumber, Structural Composite Lumber (SCL), Type I Foam

#### Cores:

Duraflake, Response Engineered Core

#### Unfinished Door Surfaces:

Hardboard, MDO and Veneer